NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014533-R1**
DATE:	**10/17/2019**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Renaissance**
CODE:	**2592-1**
REVISION DATE:	**06/15/2023**

To This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. **13340 International Parkway** **Jacksonville, FL 32218**	**Series "8400"** **Vinyl Sliding Glass Door** (Fin or Frame Installation) Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2440mm(96") H-2440mm(96") Panel: W-1215mm(47.88") H-2370mm(93.25") DLO: W-1100mm(43.25") H-2255mm(88.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-09**	**Class LC-PG30 2440 x 2440 (96 x 96)-SD** **Design Pressure: ±1440 Pa (±30 psf)** **Water Penetration Resisitance Test Pressure: 220 Pa (4.59 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Architectural Testing, Inc.
Report No: G5681.01-901-44/W-1859
Expiration Date: **October 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com