

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014537-R2
DATE: 10/17/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Renaissance
CODE: 2592-1
REVISION DATE: 06/15/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Renaissance Windows & Doors, Inc. 13340 International Parkway Jacksonville, FL 32218	Series "9700" Vinyl Sliding Glass Door Configuration: OXXO Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray America SG Interlayer/1/8" Heat Strengthened Glass Frame: W-4877mm(192") H-2438mm(96") Panel: W-1229mm(48.37") H-2324mm(91.5") DLO: W-1048mm(41.25") H-2178mm(85.75")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing, Inc.
Report No: E0597.01-550-18
Expiration Date: October 31, 2027

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com