



MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG50-3645x2426 (144x96)-SD	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 144x96 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	Rating above conforms to the requirements of: ASTM E1886 and E1996	18523	1618 SGD (PVC)(OXX)(OG) (INS TEMP/0.100" SGP LAMINATED GL) (MODIF)(REINF)(ASTM)	<u>FRAME (mm)</u> 3645 x 2426 (12'0" x 8'0")	<u>PANEL (mm)</u> 1251 x 2286 (4'1" x 7'6")

This Certification will expire **September 6, 2024** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Molimo, LLC

Report No: **2081.03-106-12**

Date of Report: **October 14, 2019**


Missile Impact Test & Report By:

Molimo, LLC

Report No: **2081.04-106-12**

Date of Report: **October 14, 2019**

Evaluated for Certification: **October 21, 2019**


Associated Laboratories, Inc.

Authorized for Certification: **October 21, 2019**


American Architectural Manufacturers Association