

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014686-R1
DATE: 01/08/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Pella
CODE: 1735-1
REVISION DATE: 11/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pella Corporation 102 Main Street Pella, IA 50219	Series "Fixed" Vinyl Composite Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-1219mm(48") DLO: W-1816mm(71.5") H-1156mm(45.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG45 1880 x 1219 (74 x 48)-FW Design Pressure: ±2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.65 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23081-1
Expiration Date: January 31, 2034

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023