



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG60 1407x1413 (55x56)-FW Negative Design Pressure = -70 psf	PA 202			
COMPANY AND PLANT LOCATION	Rating: +60/-70, 55x56	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
MI Windows & Doors, LLC Code: MTL	Rating above conforms to requirements of: TAS 202	19320	185MD PICTURE FIN, FINLESS, FLANGE (AL) (O) (OG) (INS GL) (ASTM)	<u>FRAME(mm)</u> 1407 x 1413 (4'7" x 4'8")

1. This Certification will expire **July 16, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

Molimo LLC

Report No.: **2451.04-106-11**

Date of Report: **September 16, 2020**

TAS Test & Report by:

Molimo LLC

Report No.: **2451.02-106-11**

Date of Report: **September 11, 2020**



(Validator / Operations Administrator)

Evaluated for Certification: **November 23, 2020**

Associated Laboratories, Inc.

Authorized for Certification: **November 23, 2020**

Fenestration and Glazing Industry Alliance