AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		**RECORD OF PRODUCT TESTED**		
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG60* 1219x2438 (48x96)-FW	**PA 202**			
COMPANY AND PLANT LOCATION	Rating: **+60/-60, 48x96**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**
MI Windows & Doors, LLC Code: MTL	Rating above conforms to requirements of: **TAS 202**	**18841**	**185MD PICTURE FIN, FINLESS, FLANGE (AL) (O) (OG) (INS TEMP GL) (ASTM)**	**FRAME(mm) 1219 x 2438 (4'0" x 8'0")**

1. This Certification will expire **January 24, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

   Molimo LLC

   Report No.: **2353.01-106-11**

   Date of Report: **April 6, 2020**

   TAS Test & Report by:

   Molimo LLC

   Report No.: **2248.02-106-11**

   Date of Report: **March 10, 2020**

*****NOTE: ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED GLASS.*****

A·L·I

(Validator / Operations Administrator)

Evaluated for Certification: **April 24, 2020**

Brad Schultz

Associated Laboratories, Inc.

Authorized for Certification: **April 24, 2020**

Fenestration and Glazing Industry Alliance