



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

Attn: Rick Sawdey

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG60* 914x1930 (36x76)-H Negative Design Pressure = -70 psf	PA 202				
COMPANY AND PLANT LOCATION	Rating: +60/-70, 36x76	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	Rating above conforms to requirements of: TAS 202	18909	185MD SINGLE HUNG FIN, FINLESS, FLANGE (AL) (O/X) (OG) (INS GL) (MODIF) (ASTM)	<u>FRAME(mm)</u> 914 x 1930 (3'0" x 6'4")	<u>SASH(mm)</u> 867 x 975 (2'10" x 3'2")

1. This Certification will expire **February 3, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

Molimo LLC

Report No.: **2357.01-106-11**

Date of Report: **April 7, 2020**

TAS Test & Report by:

Molimo LLC

Report No.: **2184.02-106-11**

Date of Report: **March 17, 2020**



(Validator / Operations Administrator)

Evaluated for Certification: **April 21, 2020**

Associated Laboratories, Inc.

Authorized for Certification: **April 21, 2020**

Fenestration and Glazing Industry Alliance