

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013915.07-R2  
DATE: 12/27/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: ViWinTech  
CODE: 583-1  
REVISION DATE: 01/04/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS                                                                                 | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                               |
|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ViWinTech Windows &amp; Doors</b><br><br><b>2400 Irvin Cobb Drive</b><br><br><b>Paducah, KY 42003</b> | <b>Series "Grand Vista Sliding Door"</b><br><br><b>Vinyl Sliding Door</b><br><br>Configuration: OXXO<br>Glazing: Insulating Glass-Ext-0.1875"<br>Tempered/Laminate-0.1875" Annealed/0.090"<br>SentryGlas Plus by Kuraray/0.1875" Annealed<br><br>Frame: W-5029mm(198") H-2438mm(96")<br><br>Panel: W-1276mm(50.25") H-2356mm(92.75")<br><br>DLO: W-1054mm(41.5") H-2140mm(84.25") |

| SPECIFICATION                                                                                                        | PRODUCT RATING                                                                                                                                                                                                                                                                                                                                   |
|----------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>ASTM E1886-05/E1996-05/09</b> | <b>Class LC-PG70 5029 x 2435 (198 x 96)-SD</b><br>3.785" Sill Riser:<br>Water Penetration Resistance Test Pressure: 504 Pa (10.5 psf)<br>3.785" Sill Riser w/Insect Screen:<br>Water Penetration Resistance Test Pressure: 540 Pa (11.25 psf)<br><b>Wind Zone 4-Missile Level D</b><br><b>Design Pressure: <math>\pm 3830</math> Pa (80 psf)</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4093-01 (Spec 9)  
Expiration Date: March 31, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'Shi D'.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122