NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013915.09-R2**
DATE:	**12/27/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**ViWinTech**
CODE:	**583-1**
REVISION DATE:	**01/04/2021**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors **2400 Irvin Cobb Drive** **Paducah, KY 42003**	**Series "Grand Vista Sliding Door"** **Vinyl Sliding Door** Configuration: OXXO Glazing: Insulating Glass-Ext-0.1875" Tempered/Laminate-0.1875" Annealed/0.090" SentryGlas Plus by Kuraray/0.1875" Annealed Frame: W-5029mm(198") H-2438mm(96") Panel: W-1276mm(50.25") H-2356mm(92.75") DLO: W-1054mm(41.5") H-2140mm(84.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **ASTM E1886-05/E1996-05/09**	**Class LC-PG65 5029 x 2435 (198 x 96)-SD** **Negative Design Pressure: -3352 Pa (70 psf)** **3.285" Sill Riser:** **Water Penetration Resistance Test Pressure: 468 Pa (9.75 psf)** **Wind Zone 4-Missile Level D** **Design Pressure: ±3830 Pa (80 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4093-01 (Spec 9)
Expiration Date: **March 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122