

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014952
DATE: 09/02/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Asselin
CODE: 417-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Asselin, Inc. 2870 Peachtree Road Northwest, #714 Atlanta, GA 30305	Series "Inswing French Door" Inswing Wood Side-Hinged Door Configuration: X Glazing: IG- (Laminated Annealed/Tempered) Frame: W-2200mm(86.63") H-3048mm(120") Panel: W-1048mm(41.25") H-2997mm(118") DLO: W-918mm(36.13") H-2746mm(108.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 2210 x 3048 (87 x 120)-SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 252 Pa (5.25 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4186-5
Expiration Date: August 31, 2024

A handwritten signature in black ink, appearing to be "Shirley".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122