

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015143-R2
DATE: 01/18/2021
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 07/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3775" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-1829mm(72") Sash: W-1251mm(49.25") H-908mm(35.75") DLO: W-1162mm(45.75") H-821mm(32.33")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG40 1321 x 1829 (52 x 72)-H Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 324 Pa (6.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4193-1
Expiration Date: September 30, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023