

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015471-R2
DATE: 12/09/2021
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 02/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "NOVA" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-1829mm(72") Sash: W-1257mm(49.50") H-895mm(35.25") DLO: W-1245mm(49") H-845mm(33.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1321 x 1829 (52 x 72)-H Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T21-067
Expiration Date: August 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023