

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016627
DATE: 04/28/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3450" Vinyl Single Hung Window Configuration: O/X Glazing: IG-Exterior: 1/8" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Annealed Glass/1/8" Annealed Glass Frame: W-1320mm(52") H-1829mm(72") Sash: W-1172mm(46.13") H-907mm(35.69") DLO: W-1192mm(46.94") H-819mm(32.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 1924T0008
Expiration Date: December 31, 2028

A handwritten signature in black ink, appearing to be "Shi".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023