

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015000-R2
DATE: 10/07/2020
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 07/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3720" Vinyl Single Sliding Window w/Sill Adapter 5865 Configuration:XOX Glazing: Insulating Glass (Annealed) Frame: W-3048mm(120") H-1524mm(60") Sash: W-660mm(25.98") H-1451mm(57.12") DLO: W-1210mm(47.63") H-1396mm(54.96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class LC-PG30 3048 x 1524 (120 x 60)-HS Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: AIR-INS inc.
Report No: AI-04124-G1
Expiration Date: October 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023