

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015470-R2
DATE: 12/09/2021
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 02/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "NOVA" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass: Fixed Lite - Tempered/Active Lites: Interior - Annealed/Exterior - Tempered Frame: W-3962mm(156") H-1524mm(60") Sash: W-967mm(38.06") H-1464mm(57.63") DLO: W-1918mm(75.50") H-1446mm(56.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG25 3962 x 1524 (156 x 60)-HS Design Pressure: ±1200 Pa (±25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T21-066
Expiration Date: March 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023