

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016905
DATE: 02/23/2026
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3400" Vinyl Horizontal Sliding Window Configuration: OX Glazing: IG-Ext. 1/8" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Annealed Glass/Int. 1/8" Annealed Glass Frame: W-1829mm(72") H-1524mm(60") Panel: W-905mm(35.63") H-1454mm(57.25") DLO: W-819mm(32.25") H-1359mm(53.50")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure +50/-50 psf Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Missile Level D Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 1924T0010
Expiration Date: May 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023