

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014991-R1
DATE: 09/30/2020
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 03/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3800/3830/5000/5040/5500" Vinyl Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-310mm(35.83") H-1980mm(77.95") Vent: W-875mm(34.45") H-1937mm(76.26") DLO: W-742mm(29.21") H-1805mm(71.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class CW-PG60 910 x 1980 (36 x 78)-C Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 730 Pa (15 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Air-Ins, Inc.
Report No: AI-04124-A1
Expiration Date: September 30, 2026

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023