

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015005-R2
DATE: 10/08/2020
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1
REVISION DATE: 07/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-6300" Vinyl Tilt & Turn Terrace In-Swing Door w/Fixed Mullion & 3.25" Frame Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2132mm(83.94") H-2440mm(96.06") Panel: W-1010mm(39.76") H-2353mm(92.64") DLO: W-804mm(31.65") H-2148mm(84.57")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 A440S1-09	Class R-PG40 2132 x 2440 (84 x 96)-DASHD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 540 Pa (11.25 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: AIR-INS Inc.
Report No: AI-04118-E1
Expiration Date: October 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023