

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015090-R1
DATE: 11/16/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 703-1
REVISION DATE: 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International 1955 Powis Road West Chicago, IL 60185	Flush Glazed Inswing Fiberglass Side-Hinged Double Door Assembly (w/Glazed Sidelites) Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-2972mm(117") H-2483mm(97.75") Panel: W-1060mm(41.75") H-2419mm(95.25") Panel DLO: W-737mm(29") H-457mm(18") Sidelite DLO: W-178mm(7") H-457mm(18")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-02/14/M-14 ASTM E331-00 TAS 202-94	Positive Design Pressure: 1915 Pa (40 psf) Negative Design Pressure: 2250 Pa (47 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0803.02-19/W-2094
Expiration Date: November 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023