

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1127.22	Ultimate Double Hung Transom G2 over Ultimate Double Hung Picture G2 - 2H Mull	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1361mm Trib Width x 1759mm Span Type-MA; DP +50/-50 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	1759mm	2722mm	D9726.01-201-47	12/12/2014	3/29/2026
407-H-1127.23	Ultimate Double Hung Transom G2 over Ultimate Double Hung Picture G2 - 2H Mull	AAMA 450-10	Class LC-PG50; Size Tested 1759mm span x 1361mm trib width (69.25 Span x 48in Trib Wd) Type-MA mull-Horizontal; DP +50/-50 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	1361mm trib width	1759mm span	D9726.01-201-47	1/21/2015	3/29/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com