



Structural Performance Certification Authorization Report

Tafco Corp.

1953 North 17th Ave
Melrose Park, IL 60610, USA

Certification ID:	1299-106
Company Code:	1299
Certification Date:	1/17/2022
Revision No:	1
Revision Date:	3/21/2022
Expiration Date:	1/17/2026

Product Rating Information:

Model:	47000 Impact Single Hung		
Operator Type:	H		
Configuration:	EM, GS - 5/16" Ann Lami Mono		
Referenced Standard:	PA/TAS 201/202/203		
Product Rating:	Large Missile, DP +30/-65, 36x62		
Rated Dimensions:	Max Width:	36 in	Max Height: 62 in

Qualifying Test information:

Test Report No:	QCT21-6383.02/QCT21-6383.03d-R2
Test Report Expiration:	1/17/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

Authorized By:

Digitally signed by Jon Hill
Date: 2022.03.21 13:23:37
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/17/2022	Initial Issuance
1	3/21/2022	Revised cert to add TAS 201 and 203 results and report number, added "Mono" to Reinforcement Configuration.