

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.


Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1134.12	Ultimate MultiSlide Door Pocket IZ3 80100 (PXX)	101/I.S.2/A440-11	Class LC-PG55; Size Tested 3616mm (142") x 3061mm (120") Type-SD; DP +55/-65 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A2	3616mm	3061mm	F0402.01-201-47	9/8/2015	10/6/2015	8/12/2030
407-H-1134.13	Ultimate MultiSlide Door Pocket IZ3 80100 (PXX)	101/I.S.2/A440-08	Class LC-PG55; Size Tested 3616mm (142") x 3061mm (120") Type-SD; DP +55/-65 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A2	3616mm	3061mm	F0402.01-201-47	9/8/2015	10/6/2015	8/12/2030
407-H-1134.14	Ultimate MultiSlide Door Pocket IZ3 80100 (PXX)	ASTM E-1996-14/ ASTM E-1886-13	DP +55/-65 psf, Missile D, Wind Zone 3	3616mm	3061mm	F0402.02-201-47	9/8/2015	10/6/2015	8/12/2030

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com