

Hallmark® Certificate of Conformance and License (CCL)



Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 448


For more Information visit www.amscert.com

Website: www.sierrapacificwindows.com

TEL: 530-527-9620

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
448-H-009.12	Vinyl Casement Fixed 59-5"x 71.5" Through Frame Installation	101/I.S.2/A440-17	Class CW-PG45; Size Tested 1511mm x 1816mm Type-FW; DP +45/-45 psf; Water Test Press 360Pa (7.52psf)	1511mm	1816mm	QCT20-6051.12	1/26/2021	11/6/2030
448-H-009.13	Vinyl Casement Fixed 59-5"x 71.5" Through Frame Installation	101/I.S.2/A440-11	Class CW-PG45; Size Tested 1511mm x 1816mm Type-FW; DP +45/-45 psf; Water Test Press 360Pa (7.52psf)	1511mm	1816mm	QCT20-6051.12	1/26/2021	11/6/2030

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com