

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016466
DATE: 01/21/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem/Silverline
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline 5020 Weston Parkway Cary, North Carolina 27513	Series "1570" Vinyl Triple Awning Window Configuration: XXX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-914mm(36") Vent : W-870mm(34.25") H-860mm(33.88") DLO: W-746mm(29.38") H-737mm(29")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50 2743 x 914* (108 x 36*)-AP Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: D6239.02-109-47/D6238.02-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023