

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016467.01
DATE: 01/21/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem/Silverline
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline 5020 Weston Parkway Cary, North Carolina 27513	Series "1570/P157NPW1AW1V" Vinyl Fixed Window over Awning Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2438mm(96") Vent: W-1172mm(46.13") H-775mm(30.50") DLO: W-1045mm(41.13") H-648mm(25.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1219 x 2438* (48 x 96*)-AP Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23712-1/E5616.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023