

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016468  
DATE: 01/21/2025  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem/Silverline  
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                     | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                           |
|----------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem/Silverline</b><br><b>5020 Weston Parkway</b><br><b>Cary, North Carolina 27513</b> | <b>Series "1570"</b><br><b>Vinyl Impact Awning Window</b><br><br>Configuration: X<br>Glazing: IG: Ext. 1/8" Annealed Glass/Int. 3/32"<br>Annealed Glass/0.090" Solutia PVB Interlayer/3/32"<br>Annealed Glass<br><br>Frame: W-1219mm(48") H-914mm(36")<br>Vent: W-1168mm(46") H-864mm(34")<br>DLO: W-1041mm(41") H-737mm(29") |

| SPECIFICATION                                                                                                       | PRODUCT RATING                                                                                                                                                                                                                           |
|---------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>ASTM E1886-05</b><br><b>ASTM E1996-12</b><br><b>TAS 201/202/203-94</b> | <b>Class CW-PG50 1219 x 914 (48 x 36)-AP</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)<br><b>Missile Level D - Wind Zone 4</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Intertek, PLC  
Report No: E1112.06-109-44/E1112.05-109-44/E1112.04-109-44  
Expiration Date: **December 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023