NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016476**
DATE:	**01/29/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem/Silverline**
CODE:	**1408-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline **5020 Weston Parkway** **Cary, North Carolina 27513**	**Series "70/70NCW4"** **Vinyl Quad Outswing Casement Window** Configuration: XXXX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-1829mm(72") Vent: W-654mm(25.75") H-1780mm(70.06") DLO: W-527mm(20.75") H-1651mm(65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440S1-17**	**Class LC-PG30 2743 x 1829 (108 x 72)-C** **Design Pressure: ±1440 Pa (±30 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23832-1
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com