

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016478.01
DATE: 01/29/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem/Silverline
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline 5020 Weston Parkway Cary, North Carolina 27513	Series "1570" Vinyl Triple Casement Window Configuration: XXX Glazing: Insulating Glass (Annealed) Frame: W-1981mm(78") H-1270mm(50") Vent: W-622mm(24.50") H-1219mm(48") DLO: W-495mm(19.50") H-1092mm(43")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1981 x 1270* (78 x 50*)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: G6368.02-109-47/F2254.02-109-47
Expiration Date: January 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023