

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016478
DATE: 01/29/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem/Silverline
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline 5020 Weston Parkway Cary, North Carolina 27513	Series "1570/P157NCW3IMP" Vinyl Triple Casement Window Configuration: XXX Glazing: IG: Ext. 1/8" Annealed Glass/Int. 3/32" Annealed Glass/0.090" Saflex PVB Interlayer/3/32" Annealed Glass Frame: W-2743mm(108") H-1829mm(72") Vent: W-876mm(34.50") H-1780mm(70.06") DLO: W-749mm(29.50") H-1651mm(65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14 AAMA 506-06/08/16	Class LC-PG50 2743 x 1829 (108 x 72)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Missile Level D - Wind Zone 3 Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23937-1/NCTL-110-23557-1/D8520.01-109-47
Expiration Date: January 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023