NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016479**
DATE:	**01/29/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem/Silverline**
CODE:	**1408-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline **5020 Weston Parkway** **Cary, North Carolina 27513**	**Series "1570"** **Vinyl Casement Window** Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Vent: W-864mm(34") H-1778mm(70") DLO: W-737mm(29") H-1651mm(65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class CW-PG50 914 x 1829 (36 x 72)-C** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Intertek, PLC
Report No: F2254.02-109-47
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com