

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015212-R2
DATE: 04/14/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1
REVISION DATE: 05/07/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "FGC" Insulated Glass Skylight Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1397mm(55") H-1397mm(55") DLO: W-1156mm(45.5") H-1156mm(45.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class SKG-PG60 1397 x 1397 (55 x 55) Design Pressure: ± 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4188-3
Expiration Date: August 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@naminc.com

NOPC-03/30/2023