NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI015349
DATE: 07/29/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Elite Windows
CODE: 2782-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Elite Windows and Doors, LLC **1010 Northwest 15 Avenue** **Pompano Beach, FL 33069**	**Series "R-210"** **Aluminum Single Hung Window** Configuration: O/X Glazing: Monolithic - 3/16" Heat Strengthened Glass/0.090" Kuraray Sentryglas Interlayer/3/16" Heat Strengthened Glass or 3/16" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/3/16" Heat Strengthened Glass or Insulated Glass - 5/32" Heat Strengthened Glass/5/32" Heat Strengthened Glass/0.090" Kuraray Sentryglas Interlayer/5/32" Heat Strengthened Glass or Insulated Glass - 5/32" Heat Strengthened Glass/5/32" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/5/32" Heat Strengthened Glass Frame: W-1067mm(42") H-2286mm(90") DLO: W-905mm(35.63") H-1029mm(40.5")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	**Design Pressure: ±4309 Pa (±90 psf)** **Water Penetration Resistance Test Pressure: 646 Pa (13.5 psf)** **Large Missile Impact Rated**

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-BEY-20-006
Expiration Date: **April 30, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122