NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI015345.02
DATE: 07/29/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Elite Windows
CODE: 2782-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Elite Windows and Doors, LLC **1010 Northwest 15 Avenue** **Pompano Beach, FL 33069**	**Series "R-220"** **Aluminum Horizontal Sliding Window** Configuration: XOX Glazing: Monolithic- 3/16" Heat Strengthened Glass/0.090" Trosifol PVB Interlayer/3/16" Heat Strengthened Glass or 3/16" Heat Strengthened Glass/0.090" Sentryglas Interlayer/3/16" Heat Strengthened Glass Frame: W-2742mm(107.94") H-1778mm(70") DLO: W-797mm(31.38") H-1572mm(62.69")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	**Design Pressure: ±4788 Pa (±100 psf)** **Water Penetration Resistance Test Pressure: 718 Pa (15 psf)** **Large Missile Impact Rated**

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-BEY-20-001
Expiration Date: **October 31, 2024**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122