

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015428.01
DATE: 09/21/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Valda
CODE: 2773-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Valda 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "Vision" Vinyl Double Dual Action Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-2438mm(96") H-1981mm(78") Vent: W-1181mm(46.50") H-1918mm(75.50") DLO: W-984mm(38.75") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class CW-PG50 2438 x 1981 (96 x 78)-DAW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 468 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4220-03A
Expiration Date: May 31, 2025

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122