NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI015464.08-R1
DATE: 12/21/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 703-1
REVISION DATE: 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International **1955 Powis Road** **West Chicago, IL 60185**	**Opaque Inswing Fiberglass** **Side-Hinged Door Assembly** **(w/Wood or WorldWide Composite Frames)** Configuration: X Frame: W-953mm(37.5") H-2076mm(81.75") Panel: W-908mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 **ASTM E1886-13a** **ASTM E1996-14a**	**Positive Design Pressure: 2873 Pa (60 psf)** **Negative Design Pressure: 3112 Pa (65 psf)** **Missile Level D**

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0830.01-21/W-1815/W-2015
Expiration Date: **September 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com