

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015464.14-R1
DATE: 12/21/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 703-1
REVISION DATE: 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International 1955 Powis Road West Chicago, IL 60185	Inswing Fiberglass Side-Hinged Door Assembly w/Glazed Sidelites (w/Wood or WorldWide Composite Frames) Configuration: OXXO Glazing: Insulated Glass (Tempered) Frame: W-3785mm(149") H-2076mm(81.75") Panel: W-908mm(35.75") H-2013mm(79.25") S/L DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E1886-13a ASTM E1996-14a	Design Pressure: ± 2394 Pa (± 50 psf) Missile Level D (Doors Only/Sidelites Excluded)

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0901.02-21/W-1815/W-2015
Expiration Date: September 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com