

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015623.01
DATE: 07/12/2022
CERTIFICATION PROGRAM: Structural
COMPANY: FBS
CODE: 2501-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
FBS Fortified and Ballistic Security 3350 NW Boca Raton Blvd Suite A28 Boca Raton, Florida 33431	Series "Hurricane Test - Fixed Window" Steel Twin Fixed Window Configuration: OO Glazing: Monolithic - 3/16" Annealed Glass/0.030" Kuraray PVB/3/16" Annealed Glass/**6mm Polycarbonate by Sabic/Monolithic - 3/16" Annealed Glass/0.030" Kuraray PVB /3/16" Annealed Glass **Polycarbonate Options: 6mm, 10mm, 12mm, or 15mm Frame: W-3721mm(146.50") H-2920mm(114.96") DLO: W-1720mm(67.72") H-2720mm(107.09")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ± 3360 Pa (± 70 psf) Water Penetration Resistance Test: 503 Pa (10.50 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing Lab
Report No: BW-FBS-21-001
Expiration Date: March 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com