



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

MI Windows & Doors, LLC  
P.O. Box 370  
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATION                                                   | RECORD OF PRODUCT TESTED |                                                                                 |                                                  |
|-----------------------------------------------------------------|--------------------------|---------------------------------------------------------------------------------|--------------------------------------------------|
|                                                                 |                          |                                                                                 |                                                  |
| AAMA/WDMA/CSA 101/I.S. 2/A440-11<br>R-PG50-1981x1219 (78x48)-FW |                          |                                                                                 |                                                  |
| COMPANY AND CODE                                                | CPD NO.                  | SERIES MODEL & PRODUCT DESCRIPTION                                              | MAXIMUM SIZE TESTED                              |
| MI Windows & Doors, LLC<br>Code: MTL                            | 15247                    | 4300 SP PW (FIN & FINLESS)<br>(PVC)(O)(IG)<br>(INS 0.090" PVB LAM GL)<br>(ASTM) | <u>FRAME</u><br>1981 mm x 1219 mm<br>(78" x 48") |

This Certification will expire **March 16, 2031 (extended from March 16, 2026 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Intertek-ATI**

Report No.: **F6071.01-109-47**

Date of Report: **April 14, 2016 (Revised April 20, 2016)**

Date Test Completed: **March 16, 2016**

Evaluated for Certification: **January 13, 2026**

  
Associated Laboratories, Inc.

Authorized for Certification: **January 13, 2026**

  
Fenestration and Glazing Industry Alliance  
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)

ACP-04 (Rev. 5/24)



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**MI Windows & Doors, LLC**  
**P.O. Box 370**  
**Gratz, PA 17030-0370**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS                                                         |                                                                                           | RECORD OF PRODUCT TESTED |                                                                                                                           |                                                                |
|------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|--------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11<br/>R-PG50-1981x1219 (78x48)-FW</b> | <b>AAMA 506</b>                                                                           |                          |                                                                                                                           |                                                                |
| COMPANY AND CODE                                                       | Missile Level: <b>D</b><br>Rating: <b>+50/-50, 78x48</b><br>Wind Zone: <b>3</b>           | CPD<br>NO.               | SERIES MODEL &<br>PRODUCT DESCRIPTION                                                                                     | MAXIMUM SIZE TESTED                                            |
| <b>MI Windows &amp; Doors, LLC</b><br><b>Code: MTL</b>                 | Rating above conforms<br>to the requirements of:<br><b>ASTM E1886</b><br><b>and E1996</b> | <b>15248</b>             | <b>4300 SP PW</b><br><b>(FIN &amp; FINLESS)</b><br><b>(PVC)(O)(IG)</b><br><b>(INS 0.090" PVB LAM GL)</b><br><b>(ASTM)</b> | <b>FRAME</b><br><b>1981 mm x 1219 mm</b><br><b>(78" x 48")</b> |

This Certification will expire **March 16, 2031 (extended from March 16, 2026 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Intertek-ATI**

Report No: **F6071.01-109-47**

Date of Report: **April 14, 2016 (Revised April 20, 2016)**

Date Test Completed: **March 16, 2016**

Missile Impact Test & Report By:


**Intertek-ATI**

Report No: **F6071.02-109-47**

Date of Report: **April 14, 2016 (Revised April 20, 2016)**

Date Test Completed: **March 16, 2016**

Evaluated for Certification: **January 13, 2026**

  
Associated Laboratories, Inc.

Authorized for Certification: **January 13, 2026**

  
Fenestration and Glazing Industry Alliance  
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**MI Windows & Doors, LLC**  
**P.O. Box 370**  
**Gratz, PA 17030-0370**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS                                                         |                                                                                           | RECORD OF PRODUCT TESTED |                                                                                                                           |                                                                |
|------------------------------------------------------------------------|-------------------------------------------------------------------------------------------|--------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11<br/>R-PG50-1981x1219 (78x48)-FW</b> | <b>AAMA 506</b>                                                                           |                          |                                                                                                                           |                                                                |
| COMPANY AND CODE                                                       | Missile Level: <b>D</b><br>Rating: <b>+50/-50, 78x48</b><br>Wind Zone: <b>3</b>           | CPD<br>NO.               | SERIES MODEL &<br>PRODUCT DESCRIPTION                                                                                     | MAXIMUM SIZE TESTED                                            |
| <b>MI Windows &amp; Doors, LLC</b><br><b>Code: MTL</b>                 | Rating above conforms<br>to the requirements of:<br><b>ASTM E1886</b><br>and <b>E1996</b> | <b>17200</b>             | <b>4300 SP PW</b><br><b>(FIN &amp; FINLESS)</b><br><b>(PVC)(O)(IG)</b><br><b>(INS 0.090" PVB LAM GL)</b><br><b>(ASTM)</b> | <b>FRAME</b><br><b>1981 mm x 1219 mm</b><br><b>(78" x 48")</b> |

This Certification will expire **March 16, 2031 (extended from March 16, 2026 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Intertek-ATI**

Report No: **F6071.01-109-47**

Date of Report: **April 14, 2016 (Revised April 20, 2016)**

Date Test Completed: **March 16, 2016**

Missile Impact Test & Report By:


**Intertek-ATI & Molimo, LLC**

Report No: **F6071.02-109-47 & 1413.03-106-12**

Date of Reports: **April 20, 2016 & January 24, 2018**

Date Tests Completed: **March 16, 2016 & December 19, 2017**

Evaluated for Certification: **January 13, 2026**

  
Associated Laboratories, Inc.

Authorized for Certification: **January 13, 2026**



Fenestration and Glazing Industry Alliance  
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)