

Hallmark® Certificate of Conformance and License (CCL)




Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449
For more Information visit www.amscert.com
Website: www.weathershield.com
TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
449-H-123.00	4201 Casement 36"x 84"	101/I.S.2/A440-17	Class LC-PG50; Size Tested 914 mm x 2134mm Type-C; DP +50/-50 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	914 mm	2134mm	QCT21-6361.04	11/16/2021	9/22/2031
449-H-123.01	4201 Casement 36" x 84"	101/I.S.2/A440-11	Class LC-PG50; Size Tested 914 mm x 2134mm Type-C; DP +50/-50 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	914 mm	2134mm	QCT21-6361.04	11/16/2021	9/22/2031
449-H-123.02	4201 Casement 36" x 84" 2-wide	101/I.S.2/A440-17	Class LC-PG50; Size Tested 914 Tributary Width x 2134 Span Type-MA; DP +50/-50 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	914 Tributary Width	2134 Span	QCT21-6361.04	11/16/2021	9/22/2031
449-H-123.03	4201 Casement 36" x 84" 2-wide	101/I.S.2/A440-11	Class LC-PG50; Size Tested 914 Tributary Width x 2134 Span Type-MA; DP +50/-50 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	914 Tributary Width	2134 Span	QCT21-6361.04	11/16/2021	9/22/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com