

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015604.13-R1
DATE: 07/21/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 12/12/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group Simonton Windows 5020 Weston Parkway, Suite 300 Cary, NC 27513	<p style="text-align: center;">Series "Perspective & MaxView"</p> <p style="text-align: center;">Vinyl Sliding Glass Door</p> <p style="text-align: center;">(2-Track w/Exterior Pocket)</p> <p style="text-align: center;">Configuration: XX-XXP</p> <p style="text-align: center;">Glazing: Insulating Glass-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened Glass or 3/16" Tempered Glass/5/32" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/5/32" Heat Strengthened Glass</p> <p>Frame: W-8788mm(346") H-2438mm(96")</p> <p>Panel: W-1524mm(60") H-2365mm(93.13")</p> <p>DLO: W-1295mm(51") H-2137mm(84.13")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-05/12/13a ASTM E1996-12/12a/14	Class LC-PG50 8788 x 2438 (346 x 96)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Missile Level D

Product Tested By: Molimo Architectural Product Testing
 Report No: 3137.07-106-11/W-2035/W-2036
 Expiration Date: **December 31, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com