NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015832.15	
08/03/2023	
Structural	
Ply Gem	
1408-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Ply Gem Window Group	Series "Ply Gem Perspective/	
Simonton Windows	Simonton MaxView"	
520 Weston Parkway, Suite 300	Vinyl Sliding Glass Door	
Cary, NC 27513		
	Configuration: XXXX Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Sentry Glass Interlayer/1/8" Heat Strengthened Glass	
	Frame: W-5937mm(233.75") H-2426mm(95.5")	
	Panel: W-1527mm(61.13") H-2364mm(93.06")	
	DLO: W-1324mm(52.13") H-2137mm(84.06")	

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-12/19 ASTM E1996-17/20	Class LC-PG70 5931 x 2438 (234 x 96)-SD Design Pressure: ±3360 Pa (±70 psf) Positive Design Pressure: 3360 Pa (70 psf) Negative Design Pressure: 3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 510 Pa (10.66 psf) Wind Zone 3 - Missile Level D

Product Tested By: Report No: Expiration Date: Molimo Architectural Product Testing 11835.05-106-11/W-2073 December 31, 2026

December 31, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: <u>nami@namiinc.com</u>