

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015832.19
DATE: 07/30/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Ply Gem Window Group Simonton Windows 5020 Weston Parkway, Suite 300 Cary, NC 27513</p>	<p style="text-align: center;">Series “Ply Gem Perspective/ Simonton MaxView”</p> <p style="text-align: center;">Vinyl Sliding Glass Door</p> <p style="text-align: center;">(3-Track w/Exterior pocket)</p> <p style="text-align: center;">Configuration: XXX-XXXXP Glazing: Insulating Glass (Tempered)</p> <p>Frame: W-7126mm(280.56") H-2426mm(95.5")</p> <p>Panel: W-1248mm(49.13") H-2364mm(93.06")</p> <p>DLO: W-1019mm(40.13") H-2137mm(84.13")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 202-94</p>	<p>Design Pressure: ±2879 Pa (±60 psf) Positive Design Pressure: 2879 Pa (60 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)</p>

Product Tested By: Molimo Architectural Product Testing
 Report No: 11835.10-106-12/W-2077
 Expiration Date: **January 31, 2027**

Administrator’s Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com