NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015832.25-R1

DATE: 09/11/2023

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Ply Gem

CODE: 1408-1

REVISION DATE: 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group	Series "Ply Gem Perspective/
Simonton Windows	Simonton MaxView"
520 Weston Parkway, Suite 300	Vinyl Sliding Glass Door
Cary, NC 27513	(3-Track w/Exterior pocket)
	Configuration: XXX-XXXP Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Sentry Glass Interlayer/1/8" Heat Strengthened Glass or IG-3/16" Tempered Glass/5/32" Heat Strengthened Glass/0.090" Sentry Glass Interlayer/5/32" Heat Strengthened Glass
	Frame: W-8955mm(352.56") H-2426mm(95.5")
	Panel: W-1553mm(61.13") H-2364mm(93.06")
	DLO: W-1324mm(52.13") H-2137mm(84.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-16	Class LC-PG70 8966 x 2438 (353 x 96)-SD
AAMA/WDMA/CSA 101/I.S.2/A440-17	Design Pressure: ±3360 Pa (±70 psf)
ASTM E1886-19	Positive Design Pressure: 3360 Pa (70 psf)
ASTM E1996-20	Negative Design Pressure: 3840 Pa (80 psf)
	Water Penetration Resistance Test Pressure: 510 Pa (10.66 psf)
	Wind Zone 3 - Missile Level D

Product Tested By: Molimo Architectural Product Testing Report No: 11835.03-106-12/W-2079/W-2082

Expiration Date: February 28, 2027

Administrator's Signature: ____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com