NOTICE OF PRODUCT CERTIFICATION

NOSS ACCREDITED A		
y on the office	CERTIFICATION NO:	<u>NI015832.26-R1</u>
NOS NIN STATES	DATE:	09/11/2023
(NAMI)	CERTIFICATION PROGRAM:	<u>Structural</u>
(Mar Charles	COMPANY:	<u>Ply Gem</u>
Adgement INSTIT	CODE:	<u>1408-1</u>
ERTIFIED PRODUCT	REVISION DATE:	09/11/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Ply Gem Window Group	Series "Ply Gem Perspective/	
Simonton Windows	Simonton MaxView"	
520 Weston Parkway, Suite 300	Vinyl Sliding Glass Door	
Cary, NC 27513	(3-Track w/Exterior pocket)	
	Configuration: XXX-XXXP Glazing: IG-1/8 Tempered Glass/1/8" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened Glass	
	Frame: W-7126mm(280.56") H-2426mm(95.5")	
	Panel: W-1248mm(49.13") H-2364mm(93.06")	
	DLO: W-1019mm(40.13") H-2137mm(84.13")	

SPECIFICATION	PRODUCT RATING
AAMA 506-16	Class LC-PG60 7137 x 2438 (281 x 96)-SD
AAMA/WDMA/CSA 101/I.S.2/A440-17	Design Pressure: ±2879 Pa (±60 psf)
ASTM E1886-19	Positive Design Pressure: 2879 Pa (60 psf)
ASTM E1996-20	Negative Design Pressure: 3112 Pa (65 psf)
	Water Penetration Resistance Test Pressure: 440 Pa (9.2 psf) Wind Zone 3 - Missile Level D

Product Tested By: Report No: Expiration Date: Molimo Architectural Product Testing 11835.10-106-12/W-2079/W-2082 January 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124 nami@namiinc.com