## **NOTICE OF PRODUCT CERTIFICATION**

NO65 ACCREDITED A		
S Star Strate C	<b>CERTIFICATION NO:</b>	<u>NI015832.27-R1</u>
Nog NIN AND NOT AN	DATE:	09/11/2023
NAMI	<b>CERTIFICATION PROGRAM:</b>	<u>Structural</u>
With Charles	<b>COMPANY:</b>	<u>Ply Gem</u>
C. AGEMENT INSTIT	CODE:	1408-1
ERTIFIED PRODUC	<b>REVISION DATE:</b>	09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	<b>PRODUCT DESCRIPTION</b>	
Ply Gem Window Group	Series "Ply Gem Perspective/	
Simonton Windows	Simonton MaxView"	
520 Weston Parkway, Suite 300	Vinyl Sliding Glass Door	
Cary, NC 27513	(3-Track w/Interior Pocket)	
	Configuration: XXX-XXXP Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened Glass or IG-3/16" Tempered Glass/5/32" Heat Strengthened Glass/0.105" Eastman Saflex PVB Interlayer/5/32" Heat Strengthened Glass	
	Frame: W-7126mm(280.56") H-3035mm(119.5")	
	Panel: W-1248mm(49.13") H-2975mm(117.13")	
	DLO: W-1019mm(40.13") H-2746mm(108.13")	

SPECIFICATION	PRODUCT RATING
AAMA 506-16	Class LC-PG50 7137 x 3048 (281 x 120)-SD
AAMA/WDMA/CSA 101/I.S.2/A440-17	Design Pressure: ±2400 Pa (±50 psf)
ASTM E1886-19	Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)
ASTM E1996-20	Wind Zone 3 - Missile Level D

Product Tested By: Molimo Architectural Product Testing Report No: 11835.12-106-11/W-2079/W-2082 Expiration Date: February 28, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND **MANAGEMENT INSTITUTE, INC.** 4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com