

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015832.28-R1
DATE: 09/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group Simonton Windows 520 Weston Parkway, Suite 300 Cary, NC 27513	<p style="text-align: center;">Series "Ply Gem Perspective/ Simonton MaxView"</p> <p style="text-align: center;">Vinyl Sliding Glass Door</p> <p style="text-align: center;">(3-Track w/Interior Pocket)</p> <p style="text-align: center;">Configuration: XXX-XXXX Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Sentry Glass Interlayer/1/8" Heat Strengthened Glass or IG-3/16" Tempered Glass/5/32" Heat Strengthened Glass/0.090" Sentry Glass Interlayer/5/32" Heat Strengthened Glass</p> <p>Frame: W-8955mm(352.56") H-2426mm(95.5")</p> <p>Panel: W-1553mm(61.13") H-2364mm(93.06")</p> <p>DLO: W-1324mm(52.13") H-2134mm(84")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA 506-16 AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-19 ASTM E1996-20</p>	<p style="text-align: center;">Class LC-PG70 8966 x 2438 (353 x 96)-SD</p> <p style="text-align: center;">Design Pressure: ±3360 Pa (±70 psf)</p> <p style="text-align: center;">Positive Design Pressure: 3360 Pa (70 psf)</p> <p style="text-align: center;">Negative Design Pressure: 3840 Pa (80 psf)</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 510 Pa (10.66 psf)</p> <p style="text-align: center;">Wind Zone 3 - Missile Level D</p>

Product Tested By: Molimo Architectural Product Testing
 Report No: 11835.13-106-11/W-2079/W-2082
 Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com