

Hallmark® Certificate of Conformance and License (CCL)

Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 448

For more Information visit www.amscert.com

Website: www.sierrapacificwindows.com

TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
448-H-004.58	Vinyl Casement 3-Wide 117.5"x 95.5" 71.5" w/23.5" high Awning & Fixed Below	35.5/35.5/45.5"x 101/I.S.2/A440-17	Class LC-PG50; Size Tested 1041mm TW x 2426mm Span Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1041mm TW	2426mm Span	QCT22-66663.01	2/1/2023	6/21/2032
448-H-004.59	Vinyl Casement 3-Wide 117.5"x 95.5" 71.5" w/23.5" high Awning & Fixed Below	35.5/35.5/45.5"x 101/I.S.2/A440-11	Class LC-PG50; Size Tested 1041mm TW x 2426mm Span Type-MA; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1041mm TW	2426mm Span	QCT22-66663.01	2/1/2023	6/21/2032

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:

John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By:

Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:

Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:

Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com