

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015729-R1  
DATE: 02/06/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 08/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                            | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                             |
|-------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>JELD-WEN</b><br><b>3737 Lakeport Boulevard</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "F4500 Swinging Door"</b><br><b>Fiberglass Direct Glazed Outswing</b><br><b>Side Hinged Door</b><br><br>Configuration: XX<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1816mm(71.50") H-1984mm(78.13")<br>Panel: W-876mm(34.50") H-1949mm(76.75")<br>DLO: W-673mm(26.50") H-1740mm(68.50") |

| SPECIFICATION                                                                                            | PRODUCT RATING                                                                                                                                                                                                                                                                                                                         |
|----------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>CSA A440S1-17</b> | <b>Class R-PG50 1816 x 1984 (72 x 78)-SHD</b><br><b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Positive Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 2640 Pa (55 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A2</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-23-002/NCTL-310-23-008  
Expiration Date: January 31, 2030

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023