AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1880x1575 (74x62)-HS Negative Design Pressure = -55 psf	**TAS 201, 202, 203**				
COMPANY AND CODE	Missile Level: **Large** Rating: **+50/-55, 74x62**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: **TAS 201, TAS 202, and TAS 203**	**22355**	**PREMIUM ATLANTIC VINYL HS (FIN & FLANGE) (PVC)(OX)(OG) (INS 0.090" SGP LAM GL) (REINF)(ASTM)**	**FRAME (mm)** **1880 x 1575 (74" x 62")**	**SASH (mm)** **940 x 1505 (37" x 59")**

This Certification will expire **August 4, 2027 (extended from August 30, 2025 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

National Certified Testing Laboratories

Report No: **NCTL-210-3895-1A**

Date of Report: **August 11, 2013**
Date Test Completed: **August 5, 2013**

Missile Impact Test & Report By:

National Certified Testing Laboratories

Report No: **NCTL-210-3895-01**

Date of Report: **August 11, 2013**
Date Test Completed: **August 4, 2013**

Evaluated for Certification: **February 20, 2025**

Associated Laboratories, Inc.

Authorized for Certification: **February 19, 2025**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)