

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009135.01-R4
DATE: 10/12/2007
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 11/15/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN Doors 3737 Lakesport Boulevard Klamath Falls, OR 97601	Jeld-Wen's "IWP Aurora" Folding Impact Rated Fiberglass Doors w/Five Panels Configuration: XXXXX Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-4648mm(183.00") H-2534mm(99.75") Panel: W-915mm(36.00") H-2438mm(96.00") DLO: W-654mm(25.75") H-2094mm(82.44")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00/E547-00 ASTM E1886-05/E1996-05 AAMA 1304-02/F842-04	Design Pressure: +45/-45 psf Wind Zone 3 - Missile Level D FER-Passed

Product Tested By: Architectural Testing, Inc.
Report No: ATI-74310.01-301-44
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122